



**PUBLIC CODE CHANGE PROPOSAL FORM
FOR PUBLIC PROPOSALS IN THE INTERNATIONAL CODES**

2009/2010 CODE DEVELOPMENT CYCLE

CLOSING DATE: All Proposals Must Be Received by June 1, 2009

The 2009/2010 Code Development Hearings are tentatively scheduled for
October 24-November 11, 2009, Baltimore, MD.

Name: Jim Buckley		Date: June 1, 2009	
Jurisdiction/Company: Buckley Rumford Co.			
Submitted on Behalf of: Masonry Alliance for Codes and Standards (MACS) & Clay Flue Lining Institute (CFLI)			
Address: 1035 Monroe Street			
City: Port Townsend		State: WA	Zip Code: 98368
Phone: 360 385 9974	Ext.	Fax: 360 385 1624	
E-mail address: buckley@rumford.com			

Code: IBC 2113.20 -09/10

Proponent: Jim Buckley, Buckley Rumford Co., representing the Masonry Alliance for Codes and Standards (MACS) & Clay Flue Lining Institute (CFLI)

Revise as follows:

2113.20 Chimney fireblocking. All spaces between chimneys and floors and ceilings through which chimneys pass shall be fireblocked with noncombustible material securely fastened in place. The fireblocking of spaces between wood joists, beams or headers shall be ~~to a depth of 1 inch (25 mm) and shall only self-supporting or~~ be placed on strips of metal or metal lath laid across the spaces between combustible material and the chimney.

Reason: To be consistent with R1003.19.

Cost Impact: The code change proposal will not increase the cost of construction.

Public Hearing: Committee: AS AM D
Assembly: ASF AMF DF