



**PUBLIC CODE CHANGE PROPOSAL FORM
FOR PUBLIC PROPOSALS IN THE INTERNATIONAL CODES**

2009/2010 CODE DEVELOPMENT CYCLE

CLOSING DATE: All Proposals Must Be Received by June 1, 2009

The 2009/2010 Code Development Hearings are tentatively scheduled for
October 24-November 11, 2009, Baltimore, MD.

Name: Jim Buckley		Date: June 1, 2009	
Jurisdiction/Company: Buckley Rumford Co.			
Submitted on Behalf of: Masonry Alliance for Codes and Standards (MACS) & Clay Flue Lining Institute (CFLI)			
Address: 1035 Monroe Street			
City: Port Townsend		State: WA	Zip Code: 98368
Phone: 360 385 9974	Ext.	Fax: 360 385 1624	
E-mail address: buckley@rumford.com			

Code: R1004.3 –09/10

Proponent: Jim Buckley, Buckley Rumford Co., representing the Masonry Alliance for Codes and Standards (MACS) & Clay Flue Lining Institute (CFLI)

Revise as follows:

R1004.3 Decorative shrouds. Decorative shrouds shall not be installed at the termination of air-cooled chimneys for factory-built fireplaces listed to UL127 except where the shrouds are listed and labeled for use with the specific factorybuilt fireplace system and installed in accordance with the manufacturers installation instructions.

Reason: Add the words "air-cooled" and "listed to UL127" as non listed decorative shrouds can interfere with the air flow of air-cooled metal chimneys listed to UL 127 for factory-built fireplaces. There is no problem, however, adding decorative shrouds to insulated factory-built chimneys listed to UL 103 that are used for masonry fireplaces, stoves, furnaces and many other appliances. The language here should be specific to aircooled UL 127 chimneys and distinguished from insulated Class A chimneys specified in Section R1005.

Cost Impact: The code change proposal will not increase the cost of construction.

Public Hearing: Committee: AS AM D
Assembly: ASF AMF DF